

Safety Equipment Monthly Inspection Record

Please be advised that British Columbia Fire Code requires that all emergency systems and equipment must be serviced and tested in accordance with Part 6 of the Code. It is the responsibility of the owner or representative to arrange for the necessary annual maintenance and testing of your building emergency systems by certified technicians.

For your convenience we have included the following monthly maintenance and test log for your records. Please complete as required and store in a safe location.

Main Fire Alarm main panel. Inspect monthly

Suite Smoke Detectors

Fire extinguishers

Emergency lights

Exit lights

Exit doors

Sprinkler Standpipe

Kitchen Hoods